

From Fire Station Officer
Fire Station Thanester

To M/s SARVJEET SINGH
121 SECTOR 5 NEAR PARSHURAM COLLEGE KURUKSHETRA
Memo No. FS/2019/57 dated : 05/12/2019

Subject : No objection Certificate Under 15 mtrs. from the fire safety point of view for Group B-Educational Building at VILL ISMAILABAD DISTT KURUKSHETRA of ANIL KUMAR D A V PUBLIC SCHOOL :

Reference your letter no. 110721923000013 dated 04/12/2019 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
ANIL KUMAR D A V PUBLIC SCHOOL	2	8	8772
Basement Level	Basement Area	Basement Remarks	

- 1) All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 2) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 3) If any lapse or non functioning of fire system will be the sole responsibility of the owner/occupier.
- 4) All the means of escape shall be kept free of all the type of obstruction all the time.
- 5) All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 6) NOC granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 7) This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 8) The owner/occupier shall strictly follow the other applicable rules/by laws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions, This fire NOC will be deemed cancelled and you will be liable to be punish as per Fire Act-2009, chapter- 3, section- 31, sub-section 1 and 2.
- 9) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

The above NOC is valid for only **One** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- Application Updated



Fire Station Officer,
Fire Station Thanester

Exercising the power of Director, Fire Services, Haryana



Digitally signed by RAJBIR SINGH
Date: 2019.12.05 10:00:53 +05:30
Reason: Digital Verification

✓ 90347-42701.

Email : kkrbestfire@gmail.com

BEST FIRE SAFETY

B S

Daels in. All Type of fire Extinguisher's, Accessories & Refilling
S.C.O. No. 1, Krishana Mkt. Sec. 7, Kurukshetra

Ref. No. **B S** 2836.

Date... 9-July-19.

CERTIFICATE

It is to certify that the New/Refilled fire extinguishers which are given / Refilled by the firm in the premises of M/s. A. K. D. A. V. Public School, Ismailabad, ^{KKR,} now are in working condition.

The efficiency of these fire extinguishers depends upon the handing so it is advised that these fire extinguishers must be checked every month.

THIS CERTIFICATE IS VALID UP TO ONE YEAR FROM THE DATE OF ISSUE.

Sr. No.	Type	Quantity	Capacity	Refill On Date	Next Due Date
1	ABC Type Dry Chemical Powder	11.	9kg + 5kg 3pc 8pc.	9.7.19.	8.7.20. ✓
2	Co ₂ Type	1.	4.5kg.	9.7.19.	8.7.20. ✓
3	M.foam.	3.	9ltr.	9.7.19.	8.7.20. ✓
4.	Abc Type	10.	2kg.	9.7.19.	8.7.20. ✓
5.	Abc Type	1.	4kg.	9.7.19.	8.7.20. ✓

Authorised Signatory

M/S BEST FIRE SAFETY
P. Sharma
Proprietor

9.7.19.