

No. GH/2019/.....729.....

Date: 23/5/19....


O/o Civil Surgeon, Kurukshetra

CERTIFICATE

Certified that the undersigned inspected the building of *Anil Kumar DAV Public School*

Sen. Sec. School, Ambala-Hisar Road, Ismailabad, Distt. Kurukshetra on dated 23 May 2019.

The sanitary and hygienic condition of this school building is satisfactory and fit for health point of view.

1

23/5/19
Dy. Civil Surgeon (Health)
Kurukshetra
23/5/19

GOVT.OF HARYANA



PUBLIC HEALTH ENGINEERING DEPARTMENT

PUBLIC HEALTH ENGINEERING WATER TESTING LABORATORY, KURUKSHETRA -136118

1. Sender' Address:-

Principal,
Anil Kumar DAV Public School,
Ismailabad, (Kurukshetra).

2. Source of Water Sample:-

W/T In Campus
Anil Kumar DAV Public School,
Ismailabad, (Kurukshetra).

3. WIS Collected on Date:-

25/Jun/2019

4. Received on Date:-

25.06.2019

5. Ref.No.:-

9432/25.06.2019

6. Lab. No.:-

PCP/42 /06/19

REPORT ON PHYSICO-CHEMICAL ANALYSIS OF WATER

Memo No.

447

Dated.

27/6/19

Substance/Characteristic	Result	Desirable Limit	Maximum Permissible Limit (In absence of better alternative source).
		As per :IS:10500-2012 Second Revision.	
Colour, Hazen Units	Clear	5	15
Odour	Odourless	Un objectionable.	
Turbidity, NTU	0.09	1	5
Total Dissolved Solids, mg/1	333	500	2000
Total Hardness (CaCO ₃), mg/1	40	200	600
Calcium (Ca), mg/1	12.02	75	200
Magnesium (Mg), mg/1	2.43	30	100
Total Alkalinity, mg/1	280	200	600
Iron (as Fe), mg/1	0.03	0.3	1.0
Chloride (as CL), mg/1	31.55	250	1000
Fluorides (as F), mg/1	0.66	1	1.5
Sulphates (as SO ₄), mg/1	18	200	400
Nitrate (NO ₃), mg/1	0.6	45	45
PH value	7.28	6.5--8.5	No relaxn.
Bacteriological Exam.	...0.. Coliform /100ml Water Seen	0	0

OPINION :

The above tested parameter of water Sample meets the requirement of :IS:10500-2012 (Second Revision).


CHEMIST

Public Health Engg. Department
Water Testing Lab, Kurukshetra

* Water Sample Collected by Sender' himself. * Report is not for legal purpose

SAVE WATER - CONSERVE WATER - DO NOT POLLUTE IT.

Principal
A.K. D.A.V. Public School
(Affiliated to C.B.S.E., Delhi Code No. 530382)
ISMAILABAD (KURUKSHETRA)